

THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966

THE SCHEDULE

FORM-A

(Form of application under sub-section (i)/Sub-section (2) of section 4 of the Tamil Nadu Public Buildings (licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rules 3 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966)

From

M/s Southside International School,
Door No: 2/557- D, S. No: 473, K. R. R. Nagar,
Mettamalai Village

To

The Tahsildar avl,
Sattur Taluk,
Sattur

Sir,

1. I intend to use the building/to continue to use the existing public building/to use the existing building not at present used as a public building, which is situated in the site or plot of land, Town or Revenue Survey No.....473.....
.....K. R. R. Nagar.....Street or Road...Mettamalai Village.....in the ward or division/village/Taluk/district... Virudhunagar District....and specified in the Statement enclosed, as a public building or a period of Three Years from the 31.05.2023 to 30.05.2026
2. The year of construction and the present approximate cost of construction and the purpose for which it is to be used or is being used as public building are also furnished in the statement accompanying this application.
3. I enclose a chalan for Rs.....
4. I also enclose a certificate of structural soundness in the prescribed form furnished by the **Engineer Sri. S. Sivapragasam** Registration No: **N.M. (J2)92458/87** with 1A class of District Collector, Virudhunagar.

Or

I have not enclosed the certificate of structural soundness from an Engineer.

Dated the.....

Signature of the Owner
of the building,

Enclosures:-1.Statement

2. Chalan for Rs..... towards the application fee. (Head of Account "Public Buildings Licensing Act/65/MS/Misc General Services & O.R.")

STATEMENT ACCOMPANYING FORM-A

1. Door Number of Building : Door No: 2/557 - D
2. Location (Street number, ward number,
Name of the Place ie. Corporation/
Municipality/Panchayat/Panchayat union/
Township/Contonment) : Door No: 2/557 - D, S. No: 473,
K. R. R. Nagar, Mettamalai Village, Sattur Taluk
3. Year of construction : 2014 & 2015
4. Approximate cost of construction as per
Current rate : Rs.1,50, 00,000/-
5. Purpose for which the building is being
Used or purposed to be used : Class room
6. Purpose for which the building has
Hitherto been used : Class room
7. Details of construction of the building :
(particulars) of the foundation, soil
specification of the various parts under
1. Foundation : Reinforced Cement Concrete Column footing
2. Basement : Brick masonry wall in Cement Mortar 1:5
3. Superstructure : Brick wall in Cement Mortar 1:5
4. Floor and roof are to be given : Floor: Tiles
Roof: Reinforced Cement Concrete Roof
8. Period for which license is required : Three years (31.05.2023 to 30.05.2026)
9. No. of person to be accommodated : 800 nos

Dated: 17.05.2023

Er. S. SIVPRAGASAM, BE (M.S.), P.E., MISE, FIV,
Chartered Engineer & L.I.C Panel Valuer
Signature of the ENGINEER
Government Registered Valuer
Banks, T.I.I.C. Panel Valuer
Collectorate Panel Engineer Class I A
Competent Person for Stability Certificates
A.M.T.R.S. Building, 15 North Car Street
SIVAKASI - 626 123
Cell : 98429 38734, 98421 28734

"Certificate that no addition or alternation has been made to the existing building of portion of a building for which this application has been made. I undertake to obtain a fresh license incase any addition or alternation is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the propose for which the licence was granted for the use of the building originally is changed or altered subsequently".

Form-B

(Form of certificate of Structural Soundness under Sub-Section (4) of Section 4 of the Tamil Nadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965 referred to in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement and furnish below the salient technical features:-

1.Foundation:-

- (i) Depth below ground level : 1.84 meter
- (ii) Nature of soil met with at foundation level : Soft Rock
- (iii) Pressure at foundation : 15.75 T/sq.m
- (iv) Probable safe bearing capacity of the strata met with at foundation : 25.00 T/sq.m
Hence, safe

2.Superstructures:-

- (i) Maximum stress in the most critical section of masonry and concrete : 25.75 T/sq.m
- (ii) Nature of masonry and concrete and its safe permissible stress : Reinforced Cement Concrete Column – 850 T/sq.m. Hence, safe.

The structural soundness of the building has been verified by me reference to Indian Standard Institute Loading Standards 875 (Latest Version) and other relevant. Indian Standard Code of Practice and I declare that the building is structurally sound to be Used as a Public Building for the purpose noted in the statement.

A licence may be granted for the period from 31.05.2023 to 30.05.2026 both inclusive.

Date: 17.05.2023

Registration No: **N.M. (J2)92458/87**
District Collector, Virudhunagar

Class: IA

Er.S.SIVPRAGASAM, BE (M.Sc.), F.I.E., M.I.S.E., F.I.V.,
Chartered Engineer, C Panel Valuer
Government Registered I.T. Valuer
Banks, I.T.I.E.C Panel Valuer
(Designation)
Collectorate Panel Engineer Class I A
Competent Person for Stability Certificates
A.M.T.R.S. Building, 15 North Car Street
SIVAKASI - 626 123
Cell : 98429 38734, 98421 28734

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

building Door name of the	Age of the Building	The Value of the building at the Current rates	Number of Storeys	Short description of structures State R.C.C. Framed (or) Load bearing structure	Purpose for which the building is certified for use	The period for which the building will be structurally sound	Number of persons to be accommodated	Remarks
1	2	3	4	5	6	7	8	9
International -D, S. No: 473 age,	9 years & 8 years	Rs.1,50,00,000/-	Two storeyed building	R. C. C. framed structure	Class room	Three years	800 nos	Proper & Periodical maintenanc work should be carried out.

Er. S. SIVPRAGASAM, BE (M.S.), FIE
Chartered Engineer & L.I.C Panel V
Governm
Signature of Engineer
Banks, T.I.I.C. Panel Valuer
Collectorate Panel Engineer Class
Competent Person for Stability Cer
A.M.T.R.S. Building, 15 North Car S
SIVAKASI - 626 123
Registration No: 6574, 61292458/8
District Collector, Virudhunag

Class: IA
Address: A. M. T. R. S. Buildings
15, North Car Street
Sivakasi

Form-C

(Form of certificate of Structural Soundness under Sub-Section (4) of Section 4 of the Tamil Nadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act XIII of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement and furnish below the salient technical features:-

1.Foundation:-

- (i) Depth below ground level : 1.84 meter
- (ii) Nature of soil met with at foundation level : Soft Rock
- (iii) Pressure at foundation : 15.75 T/sq.m
- (iv) Probable safe bearing capacity of the strata met with at foundation : 25.00 T/sq.m
Hence, safe


2.Superstructures:-

- (i) Maximum stress in the most critical section of masonry and concrete : 25.75 T/sq.m
- (ii) Nature of masonry and concrete and its safe permissible stress : Reinforced Cement Concrete Column – 850 T/sq.m. Hence, safe.

The structural soundness of the building has been verified by me reference to Indian Standard Institute Loading Standards 785 (Latest Version) and other relevant. Indian Standard Code of Practice and I declare that the building is structurally sound to be Used as a Public Building for the purpose noted in the statement.

A licence may be granted for the period from 31.05.2023 to 30.05.2026 both inclusive

Date: 17.05.2023



E. S. SIVAPRASAM
Signature of Engineer, B.E.(M.Sc), P.E., M.I.S.E., F.I.V.,
Chartered Engineer & L.I.C Panel Valuer
Government Registered I.T. Valuer
Banks, T.I.I.C. Panel Valuer
Collectorate Panel Engineer Class I A
Competent Person for Stability Certificates
A.M.T.R.S. Building, 15 North Car Street
SIVAKASI - 626 102

Form-E

[Form of report to be made to the competent Authority by Inspecting Authorities or officers appointed under other Acts under section 28 of the Tamilnadu Public Buildings (Licensing) Act, 1965 [Tamilnadu Act XIII of 1965] referred to in the rule 7 of the Tamilnadu Public Buildings (Licensing) Rules, 1966.]

- | | |
|---|---|
| 1. Name and designation of the Inspecting Authority of officer appointed or having Jurisdiction under any other Act or Rule. | ER. S. Sivapragasam, B.E., (civil),
Chartered Engineer & Registered Valuer.
Registration No: N.M. (J2)92458/87 |
| 2. Location of the building inspected:
Door no./ street name/name of the place
i.e. Municipality/Panchayat or Panchayat union /Township/ cantonment | M/s Southside International School,
Door No: 2/557-D, S. No: 473,
K. R. R. Nagar, Mettamalai Village,
Sattur Taluk |
| 3. Date of inspection: | 17.05.2023 |
| 4. Purpose for which the building is used | Educational Institution |
| 5. Nature of defects noticed | Nil |
| 6. Suggestions for rectifying defects | Nil |
| 7. If in dangerous conditions, immediate steps recommend to be taken | Nil |

Date: 17.05.2023


Er. S. SIVPRAGASAM, B.E., M.Sc., F.I.E., M.I.S.E., F.I.V.,
Chartered Engineer & Registered Valuer
(Officer appointed (or)
Having Jurisdiction)
Banks, T.I.I.C. Panel Valuer
Collectorate Panel Engineer Class I A
Competent Person for Stability Certificates
A.M.T.R.S. Building, 15 North Car Street
SIVAKASI - 626 123
Cell : 98429 38734, 98421 28734